

MARK	FIXTURE	TYPE	MINIMUM CONNECTION SIZE		REMARKS		
			WASTE	VENT			
WC-1	WATER CLOSET	WALL HUNG (ADA)	4"	2"	-	1'-1"	1.2
L-1	LAVATORY	WALL HUNG (ADA)	1 1/2"	1 1/2"	1/2"	1/2"	1.2
S-1	SINK	COUNTER DOUBLE BOWL	1 1/2"	1 1/2"	1/2"	1/2"	1.2
S-2	SINK	COUNTER DOUBLE BOWL	1 1/2"	1 1/2"	1/2"	1/2"	1.2
S-3	SINK	COUNTER SINGLE BOWL	1 1/2"	1 1/2"	1/2"	1/2"	1.2
S-4	SINK	SOLIDUS INTERCEPTOR	2"	2"	-	-	1.2
MSB-1	MOP SINK BASIN	FLOOR SET	3"	1 1/2"	1/2"	1/2"	1.2
ETH-1	EMERGENCY EYEWASH	COUNTERTOP MOUNTED	-	-	1/2"	1/2"	1.2
FS-1	FLOOR SINK	SEE PLANS	SEE PLANS	SEE PLANS	-	-	1.2
FO	CLEANOUT	FLOOR	-	-	-	-	1.2
WCO	CLEANOUT	WALL	-	-	-	-	1.2
GCO	CLEANOUT	GRADE	-	-	-	-	1.2
FD-1	FLOOR DRAIN	SEE PLANS	SEE PLANS	SEE PLANS	-	-	1.2
HB-1	HOSE BIBB	SEE PLANS	-	-	-	3/4"	1.2
WH-1	WALL HYDRANT	SEE PLANS	-	-	-	3/4"	1.2
VB-1	VALVE BOX	ICE MAKER	-	-	-	1/2"	1.2
VB-2	VALVE BOX	CLOTHES WASHER	1 1/2"	1 1/2"	3/4"	3/4"	1.2

**VALVE BOX: VB-2**

**EXPLITE**  
 EXPLITE SUPPLIED METAL RECESSED CABINET, COMPLETE WITH CORROSION  
 RESISTANT OILED GALVANIZED STEEL FINISH, 2" DRAIN CONNECTION, 1/2" HOT M  
 GY GRAY Z200 OR APPROVED EQUAL.

**ACCESS PANEL: AP-1**

**EXPLITE**  
 8"x8" 1/8" GAUGE STEEL DOOR AND FRAME WITH CONCEALED HINGE AND  
 J.R. SMITH 4752-0808 OR APPROVED EQUAL.

**WATER HAMMER ARRESTER: WHA-X**

**EXPLITE**  
 STOCK ASSEMBLED WITH STAINLESS STEEL SHELL, HYDRO-PNEUMATIC CUSHION OR  
 AIR CHARGED (CUSTOMER'S CHOICE), 1/2" NPT CONNECTION, 1/2" NPT  
 ADAPTER AND MALE THREADED PLUG.  
 J.R. SMITH SERIES 5000 OR APPROVED EQUAL.

TYPE NO.	P.A.I.
SIZE	FINISH
UNITS	

— — — — —

5050	F	155-310
-	-	

**EXCLUDE**  
BOTTOM SUPPLIED, METAL RECESSED CABINET, COMPLETE WITH CORROSION  
RESISTANT DIPPED GALVANIZED STEEL FINISH, 2" DRAIN CONNECTION, 1/2" HOT A  
COLD HOSE VALVES.  
GUY GRAY B200 OR APPROVED EQUAL.

**EXFURE:** 8-X-16 GAUGE STEEL DOOR AND FRAME WITH CONCEALED HINGE AND SCREWDRIVER OPERATED LATCH; TYPE 304 STAINLESS STEEL WITH NO. 4 FINISH. J.R. SMITH 4762-08X08 OR APPROVED EQUAL.

**EXTURE**  
SHOCK ABSORBER WITH STAINLESS STEEL SHELL, HYDRO-PNEUMATIC CUSHION OF ARGON GAS AND PURE GLYCERINE, ELASTOMER, BELLOWS, STAINLESS STEEL ADAPTER AND MALE THREADED PLUG.  
J.R. SMITH SERIES 5000 OR APPROVED EQUAL.

TYPE NO.	P.O.I. SITE	FIXTURE UNITS
5005	A	1-11
5010	B	12-32
5020	C	33-60
5030	D	61-113
5040	E	114-154
5050	F	155-330
-	-	

**Dwg. 31 of 37**

**EXLURE** BOTTOM SUPPLIED, METAL RECESSED CABINET, SINGLE VALVE OUTLET B CORROSION RESISTANT DIPPED GALVANIZED STEEL FINISH, 20 GAUGE 18 GAUGE FACEPLATE. ICE MAKER BOX COMPLETE WITH STOP VALVE. GUY GRAY BIM875 OR APPROVED EQUAL.

1. ALL CONTRACTORS ARE RESPONSIBLE FOR REVIEWING ENTIRE SET OF DOCUMENTS TO DETERMINE THEIR FULL SCOPE OF WORK. CONTRACTOR SHALL NOT BE ALLOWED EXTRA COSTS DUE TO FAILURE TO REVIEW ENTIRE SET OF DOCUMENTS.

2) ANY USE OF THESE ELECTRONIC DRAWINGS OR SCALING OF THE PRINTED DOCUMENTS ARE DONE SO AT THE CONTRACTORS RISK.

**AND RISER DIAGRAMS**

Construction Documents (100%) Submittal

Approved: \_\_\_\_\_ Date: \_\_\_\_\_

Reviewed: \_\_\_\_\_ Date: \_\_\_\_\_

RENOVATION/ ADDITION

VAMC Omaha, NE

Date  Checked by

Building Number: SIX  
Drawing Number: P3.1